



Town of Queensbury – Aviation Road Sidewalk Construction

LaBella Project No. 2240674.22

Addendum No. 1

August 20, 2025

This Addendum forms a part of, and modifies, the original Contract Documents titled, “Aviation Road Sidewalk Construction” dated August 4, 2025. Each Bidder shall acknowledge receipt of all addenda on the Bid Proposal form included in the Contract Documents. Failure to provide acknowledgement may subject Bidder to disqualification.

The attention of all Bidders is directed to the following modifications to the Contract Documents:

1. Clarification of Sidewalk Concrete

- The notes in Detail 1/C530 state that current NYSDOT standard specifications shall be used for the installation of the concrete sidewalk. That shall be interpreted to allow for either of the following concrete options:
 - (1) Performance Engineered Mixture (PEM) in accordance with the current NYSDOT Standard Specifications (2024 edition).
 - (2) Former NYSDOT Class D concrete meeting a minimum compressive strength of 4,500 PSI, in accordance with the NYSDOT Standard Specifications in effect prior to the adoption of PEM requirements.