

April 20, 2026

ADDENDUM NO. 2
TO CONTRACT DOCUMENTS
Jenkinsville Water Distribution System - Contract 1
Town of Queensbury

This addendum consists of two (2) pages and one (1) attachment. By issuance of this Addendum, Prospective Bidders are advised of any and all revisions, additions and/or deletions to the Contract Documents.

Revisions to the Contract Drawings:

1. Sheet C-116
 - a. The 12” gate valve has been moved from STA A93+18 to STA A93+28.
2. Sheet C-117
 - a. The 8” gate valve has been moved STA A98+32 to STA A98+22.

Revisions to the Project Manual:

1. Section 331240 – Miscellaneous Piping Accessories:
 - a. Paragraph 2.11.B.1 shall be changed from “3/4" Service, 15" diameter Meter Pit: Model No. 203CS1572FSBN” to “3/4" Service, 15" diameter Meter Pit: Model No. 203CS1572LBBLN”
 - b. Paragraph 2.11.B.2 shall be changed from “1" Service, 18" diameter Meter Pit: Model No. 330CS1872FSBN” to “1" Service, 18" diameter Meter Pit: Model No. 330CS1872LBBLN”
 - c. Paragraph 2.11.C.1 shall be changed from “Insulation pad shall be minimum 4" thickness” to “15" diameter Meter Pit:”
 - d. Add paragraph 2.11.C.1.a as follows:
 - i. Locking Cover: Model No. 780068
 - e. Add paragraph 2.11.C.1.b as follows:
 - i. Insulation Pad: Model No. 790022
 - f. Add paragraph 2.11.C.2 as follows:
 - i. 18" diameter Meter Pit:
 - g. Add paragraph 2.11.C.2.a as follows:
 - i. Locking Cover: Model No. 780069
 - h. Add paragraph 2.11.C.2.b as follows:
 - i. Insulation Pad: Model No. 790153

Clarifications:

The following RFI’s were received by prospective bidders with replies to each provided:

2. How much is the DOT Bond?

Response: It shall be assumed the DOT Bond will be \$50,000.00. This will be determined when the Contractor applies for the permit.

3. Is there a bond or special insurance requirements for the Warren County highway permit?

Response: It shall be assumed that a \$100,000.00 performance bond will be required.

4. What is the cost of the Warren County Highway Permit?

Response: There is no cost for the Warren County Highway Permit.

5. Please name the manufacturer of the pipe supplied by the owner.

Response: The DIP supplied by Owner was manufactured by Atlantic, Griffin and US Pipe.

6. Is the intent for the owner only to supply the previously purchased 2,000 LF of pipe mentioned in the spec book? Or would the owner potentially furnish more?

Response: The Owner will only furnish 2,000 LF of DIP.

7. Can a bid item for hydrant extensions be added?

Response: A bid item for hydrant extensions will not be added. It can be accounted for under the allowance, as needed.

8. What are the dates that the borings were completed?

Response: Borings were completed in January 2022.

9. Where will the contractor have access to get water for testing?

Response: Contractor will have access to water for testing at a hydrant operated by the Town.

10. Will water be provided at no cost since this is being used to test the new system?


Response: Water for testing the water main will be supplied at no cost via hydrants operated by the Town.

This addendum is hereby made a part of the Bidding and Contract Documents. Bidders are advised to acknowledge the receipt of this addendum on page 004100 – 1. Failure to do so may invalidate the Contractor's bid.

Issued

C.T. MALE ASSOCIATES

By:


James R. Edwards, P.E.
VP Risk Management



END OF ADDENDUM NO. 2